



### 10.6.3.1 Riser Entrance Location. (24:Figure A.10.6.3.1)

NO PART OF THE LEAD IN TO THE FLANGE MAY BE COVERED WITH SOIL/OVERBURDEN UNTIL APPROVED BY LOCAL AHJ/FIRE MARSHAL.