

Re: Engelhard plans for fire suppression system

Arun Mr

Tue 9/17/2019 2:22 PM

To: Bruce e <engelhard.bruce@gmail.com>

Excluding existing building.

Sprinklers for NEW building section only:

Design Permit Submit, install: \$8,800

You will need to supply water line.

Your electrician should have 1 Horn Strobe outside & at least 1 Strobe for inside, that will detect Riser water flow.

Water flow must meet Design Calcs.

Minimum payment of \$1500.00 is required in order to begin the design and permitting process.

Arun (Mr.)

Projects & Compliance

Fire Suppression Services Incorporated

3802 S. 2300 E.

Millcreek UT 84109

(801) 440-9906 Cell, (no Text)

(801) 277-6464 Main Office

When removing a panel or device from the system, record the proper jumper and address settings to insure the replacement is setup correctly.

UT Code 105 If you Add-Change-Delete or Move a Device, Head, Pipe or Wall- A City Permit is REQUIRED

There may be times when we are powerless to prevent injustice, but there must never be a time when we fail to protest

From: Bruce e <engelhard.bruce@gmail.com>

Sent: Tuesday, September 17, 2019 9:30 AM

To: Arun Mr <arunfss@live.com>

Subject: Re: Engelhard plans for fire suppression system

Thanks for getting back to me.

1. Existing structure not sprinkled, and it does not have to be

2. Breezeway not heated at this point, and no intention of doing it. That is why we don't want to sprinkle it.

3 Water supply and riser location will be directly under the stairs in the garage, in a sealed and heated utility space. It is not in as of yet, we have not started to frame, but the concrete work is done and we hope to be framing by next week.

4. Stuart Grey and Daniel Egbert have stated that they do not believe the breezeway or the attic need to be sprinkled; yet they obviously need me to get them a detailed construction document from someone like you and it needs to be 3rd party reviewed.

B

On Sep 17, 2019, at 9:22 AM, Arun Mr <arunfss@live.com> wrote:

I have a question or two:

I am looking at the Englehard Residence and have a couple of questions,

1 - Is the Existing residence sprinklered?

a - If not, does it have to be? (AHJ)

2 - Is the breezeway between the two building conditioned, (heated)?

3 - Water supply and riser location for the new building? is it in?

4 - What did AHJ Stuart Gray tell you?

Arun (Mr.)

Projects & Compliance

Fire Suppression Services Incorporated

3802 S. 2300 E.
Millcreek UT 84109
(801) 440-9906 Cell, (no Text)
(801) 277-6464 Main Office

When removing a panel or device from the system, record the proper jumper and address settings to insure the replacement is setup correctly.
UT Code 105 If you Add-Change-Delete or Move a Device, Head, Pipe or Wall- A City Permit is REQUIRED
There may be times when we are powerless to prevent injustice, but there must never be a time when we fail to protest

From: Bruce e <engelhard.bruce@gmail.com>
Sent: Tuesday, September 17, 2019 9:11 AM
To: Arun Mr <arunfss@live.com>
Subject: Re: Engelhard plans for fire suppression system

Arun,

Haven't heard anything back from you yet. I assume you are incredibly busy, but I am wondering if you need anything else from me to be able to produce that bid?

Thanks,

B

On Sep 11, 2019, at 9:43 AM, Arun Mr <arunfss@live.com> wrote:

Thank you.
Do you have a Scope of Work. or Specs?
Color etc.

Cheers

Arun (Mr.)
Projects & Compliance
Fire Suppression Services Incorporated
3802 S. 2300 E.
Millcreek UT 84109
(801) 440-9906 Cell, (no Text)
(801) 277-6464 Main Office

When removing a panel or device from the system, record the proper jumper and address settings to insure the replacement is setup correctly.
UT Code 105 If you Add-Change-Delete or Move a Device, Head, Pipe or Wall- A City Permit is REQUIRED
There may be times when we are powerless to prevent injustice, but there must never be a time when we fail to protest

From: Bruce e <engelhard.bruce@gmail.com>
Sent: Wednesday, September 11, 2019 9:32 AM
To: arunfss@live.com <arunfss@live.com>
Subject: Engelhard plans for fire suppression system