

Subject: FW: Howdy

From: Arun Mr
Sent: Tuesday, March 30, 2021 3:00 PM
To: Erick Spotten **Subject:** RE: Howdy

Who is your Client, Can you ask them if they can get the PASSWORD

Else: we have to restore panel to default, and re-program.

That panel has a lot going on in it,
and is only getting sigs from the on-board contacts.

So,
If we have to re-initialise the unit, it won't be this week.
DACTs are hard to come by right now.

Arun (Mr)
Projects & Compliance
Fire Suppression Services Inc.
3802 S 2300 E. Millcreek. UT 84109

From: Erick Spotten [<mailto:espot10@gmail.com>]
Sent: Tuesday, March 30, 2021 2:42 PM
To: Arun Mr
Subject: Re: HOWdy

Alarm Innovations
mailing address
7742 Towne Circle, Salt Lake City Utah 84121 M 801 259 9504
espot10@gmail.com

Work Address
Alarm Innovations 110 West 2950 South Salt Lake City, Utah 84115

Office 801 265 0186

St Mark's Medical Center
348 East 4500 South. Murray, UT 84047
need a DAC for
Edwards FACP
i0500 (G/R) (D)-(PG)/ -SP)

relay output
Alarm, Trouble, & Supervisory
NO 24 hour test form the FACP

Erick Spotten