


1. Dedicated Function Alarm Panel to monitor ONLY the following:
 - 1.1. Three separate chemical Suppression Systems. (Two Vehicle Paint Booths & one Mixing Room)
2. Note:

As at 2022-Dec-22, there is no fire sprinkler system servicing any part of this tenant space+Valley Collision)
3. WIRING DEPICTED ON THESE PLANS IS SCHEMATIC
4. Wiring will be MC Fire-Flex. 16-4 MPLP-MC. ETA: 15+ days
5. Power for ALL Fire Alarm panels, Fire Alarm Power Supplies (& Dialers where necessary), must be provided by a DEDICATED AC BRANCH CIRCUIT and Clearly Labeled at the breaker panel
6. Fire Alarm Panel room & its surrounding area panel must be clear of all obstructions and at no time used for storage.
7. 3-Foot distance walking space must be maintained around all spray booths. Space is not for storage.
8. Too much paint dust/powder for a 'smoke' detector
9. Chem suppression micro-switches to be changed and prepared by Bill Gubler (FSS) & made ready for Alarm Technician.
- 10.



Fire Suppression Services Inc.
3802 S. 2300 E. Millcreek
Utah 84109-3421
(801) 277-6464

Valley Collision
2521 S 300 W
SOUTH SALT LAKE CITY
UT 84115

Sean Barbieri
(801) 599-1070

Drawn by:
Arun
Date drawn:
2022-12-13
Date issued:
2023-01-06

Revisions	
Δ	2022-12-22 CONFIRM part#s
Δ	2022-??-?? Confirm Breaker position
Δ	----
Δ	----
----	----

PRECON	
Project#	FSS12322
Owner	Valley Collision
Tenant	Valley Collision
Site	2521 S 300 W South Salt Lake City UT 84115 (801) 467-5804

Drawing
FA-01



Dedicated Function Fire Alarm @ 2521 S 300 W. SSLC

Dedicated Function Fire Alarm Valley Collision.dwg

A

B

C

D

E

F

G

H

I